

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7150-1477:101 Page 1 of 1

**CATEGORY:** Boxes/Pull Stations

**LISTEE:** Mircom Technologies Ltd\*, 8111 Jane Street, Vaughan, ON, L4K 4L7, Canada  
Contact: \*Mara Cherubin (888) 660-4655 Fax (888) 660-4113

**DESIGN:** Model MS-401, MS-402, MS-405, MS-406, MS-407, MS-408, MS-501, MS-502, MS-505 and MS-507 noncoded fire alarm manual pull stations; Models 403, 404 emergency pull stations and Model MS-DA station adapter. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 30 VDC, 1A

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as fire alarm manual pull stations for use with separately listed electrically and functionally compatible fire alarm control units.

**NOTE:** Models 403 and 404 is not intended for use as fire alarm pull stations.

\*Rev. 06-18-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager